

Electrical Test Summary



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 11/01/2013 To: 07/09/2018

Asset ID	Description	Result (Including non-electrical tests)	Test Date	Visual	Earth (Ohms)	Insulation (MOhms)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Load (kVA)	Polarity	Flash (mA)	RCD (ms)
Client:		Site: DJ EQUIPMENT			Location: MOBILE DJ								
164	BLACK 4 WAY EXT	Pass	20/03/2018	P	0.05 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
165	TWO WAY EXTENSION	Pass	20/03/2018	P	0.08 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
166	TWO WAY EXTENSION	Pass	20/03/2018	P	0.06 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
167	TWO WAY EXTENSION	Pass	20/03/2018	P	0.05 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
168	TWO WAY EXTENSION	Pass	20/03/2018	P	0.09 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
169	TWO WAY EXTENSION	Pass	20/03/2018	P	0.09 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
170	TWO WAY EXTENSION	Pass	20/03/2018	P	0.09 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
171	POWER CENTER	Pass	20/03/2018	P	<0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
172	IEC LEAD	Pass	20/03/2018	P	0.11 P	89.81 P	<0.1 P	S	S	<0.05	S	S	S
173	IEC LEAD	Pass	20/03/2018	P	0.1 P	81.4 P	<0.1 P	S	S	<0.05	S	S	S
174	IEC LEAD	Pass	20/03/2018	P	0.08 P	86.24 P	<0.1 P	S	S	<0.05	S	S	S
175	IEC LEAD	Fail	20/03/2018	P	0.19 F	S	S	S	S	S	S	S	S
176	IEC LEAD	Pass	20/03/2018	P	0.07 P	84.92 P	<0.1 P	S	S	<0.05	S	S	S
177	IEC LEAD	Fail	20/03/2018	P	0.1 F	S	S	S	S	S	S	S	S
178	IEC LEAD	Fail	20/03/2018	P	0.12 F	S	S	S	S	S	S	S	S
179	LEC LEAD	Pass	20/03/2018	P	0.07 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
180	IEC LEAD	Fail	20/03/2018	P	0.1 F	S	S	S	S	S	S	S	S
181	ROUND LED LIGHT	Pass	20/03/2018	P	S	>99.99 P	S	S	S	S	S	S	S
182	ROUND LED LIGHT	Pass	20/03/2018	P	S	>99.99 P	S	S	S	S	S	S	S
183	ROUND LED LIGHT	Pass	20/03/2018	P	S	>99.99 P	S	S	S	S	S	S	S
184	ROUND LED LIGHT	Pass	20/03/2018	P	S	>99.99 P	S	S	S	S	S	S	S
185	PSYCHO STROBE LIGHT	Pass	05/09/2018	P	S	>99.99 P	S	<0.1 P	S	S	S	S	S
186	DMX SPOT BLACK 60	Pass	05/09/2018	P	0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
187	DMX SPOT BLACK 60	Pass	05/09/2018	P	0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
188	UV BAR LIGHT	Pass	05/09/2018	P	0.04 P	>99.99 P	0.32 P	S	S	<0.05	S	S	S
189	IEC LEAD	Fail	05/09/2018	P	0.14 F	S	S	S	S	S	S	S	S
190	IEC LEAD	Pass	05/09/2018	P	<0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
191	IEC LEAD	Pass	05/09/2018	P	0.05 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
192	IEC LEAD	Pass	05/09/2018	P	0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
193	IEC LEAD	Pass	05/09/2018	P	0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
194	IEC LEAD	Pass	05/09/2018	P	0.07 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
195	ACME DRAGON SCAN	Pass	05/09/2018	P	0.1 P	89.93 P	S	S	S	S	S	S	S
196	ACME DRAGON SCAN	Pass	05/09/2018	P	0.05 P	>99.99 P	S	S	S	S	S	S	S
197	IEC LEAD	Pass	05/09/2018	P	0.06 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
198	DISCO BALL	Pass	05/09/2018	P	0.09 P	>99.99 P	S	S	S	S	S	S	S
199	DISCO BALL	Pass	05/09/2018	P	0.08 P	>99.99 P	S	S	S	S	S	S	S
200	IEC LEAD	Pass	05/09/2018	P	0.05 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
201	HOT ROD LIGHTS	Pass	05/09/2018	P	0.07 P	>99.99 P	S	S	S	S	S	S	S

Electrical Test Summary



Test Status: All, Test Type: All
Person: All, Instrument: All
From: 11/01/2013 To: 07/09/2018

Asset ID	Description	Result (Including non-electrical tests)	Test Date	Visual	Earth (Ohms)	Insulation (MOhms)	Leakage (mA)	Touch Leakage (mA)	Sub Leakage (mA)	Load (kVA)	Polarity	Flash (mA)	RCD (ms)
203	MIXER DECK	Pass	05/09/2018	P	S	>99.99 P	S	S	S	S	S	S	S
204	QSC SPEAKER	Pass	05/09/2018	P	<0.04 P	>99.99 P	S	S	S	S	S	S	S
205	QSC SPEAKER	Pass	05/09/2018	P	<0.04 P	>99.99 P	S	S	S	S	S	S	S
206	ULTRAVILOET LIGHT	Pass	05/09/2018	P	0.05 P	>99.99 P	S	S	S	S	S	S	S
207	IEC LEAD	Pass	05/09/2018	P	<0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
208	IEC LEAD	Pass	05/09/2018	P	<0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
209	IEC LEAD	Pass	05/09/2018	P	<0.04 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
210	REVO4 LIGHT	Pass	05/09/2018	P	0.06 P	>99.99 P	S	S	S	S	S	S	S
211	GOBO PROJECTOR	Pass	05/09/2018	P	0.06 P	>99.99 P	S	S	S	S	S	S	S
212	SHARD PROLIGHT	Pass	05/09/2018	P	<0.04 P	>99.99 P	S	S	S	S	S	S	S
213	PROLIGHT	Pass	05/09/2018	P	<0.04 P	>99.99 P	S	S	S	S	S	S	S
214	INNO POCKETZ4	Pass	05/09/2018	P	<0.04 P	>99.99 P	S	S	S	S	S	S	S
215	INN POCKET Z4	Pass	05/09/2018	P	0.04 P	>99.99 P	S	S	S	S	S	S	S
216	IEC LEAD	Pass	05/09/2018	P	0.08 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
217	EQUINOX CONTROLLER	Pass	05/09/2018	P	0.09 P	>99.99 P	S	S	S	S	S	S	S
218	SWARM5FX LIGHT	Pass	05/09/2018	P	0.09 P	>99.99 P	S	S	S	S	S	S	S
219	SWARM 5FX LIGHT	Pass	05/09/2018	P	0.09 P	>99.99 P	S	S	S	S	S	S	S
220	PENTA PIX LIGHT	Pass	05/09/2018	P	0.11 P	>99.99 P	S	S	S	S	S	S	S
221	IEC LEAD	Fail	05/09/2018	P	0.16 F	S	S	S	S	S	S	S	S
222	LEC LEAD	Fail	05/09/2018	P	0.16 F	S	S	S	S	S	S	S	S
223	IEC LEAD	Pass	05/09/2018	P	0.09 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S
224	IEC LEAD	Pass	05/09/2018	P	0.09 P	>99.99 P	<0.1 P	S	S	<0.05	S	S	S

Total Assets: 60